

SAN • JUAN • BASIN
HEALTH
 DEPARTMENT

Permit # 463A
 Year 1999

APPLICATION to INSTALL, CONSTRUCT, ALTER or REPAIR INDIVIDUAL SEWAGE SYSTEM

Owner: MICHAEL A. BLUM Phone: 264-0018
 Mailing Address: P.O. BOX 5353 PAGOSA SPRINGS, CO 81147
 Site Address: 224 BROSS PL. / LOT 250 Assessor's Parcel # 10-34-20 589110203039-R
 Subdivision: MEADOWS III Unit 4 Block N/A Lot 250
 Lot Size: 5 AC. Living Units: 1 Bedrooms: 3 Water Supply: PAWS

Date: 9-9-99 Owner's Signature: Michael A. Blum
 I acknowledge the issuance of this permit does not imply any warranty on the part of this department to the operation of this system.
 This system will be constructed in accordance with the SJBHD individual sewage disposal system regulations.
 Permit Fee: \$ 245⁰⁰ Perc Test Fee: \$ 100⁰⁰ Rec'd By: CK # 1 245⁰⁰ Date: 9-9-99
500 Regs Box

PERMIT to INSTALL, CONSTRUCT, ALTER or REPAIR INDIVIDUAL SEWAGE SYSTEM

Percolation Rate: >60 Min/ Inch Limiting Zone: >8 Feet:
 Soil Profile: clay/shale Slope %: 4 Requires Eng. Design:
 From the application information & the site evaluation, the following minimum installation specifications are required:
 Septic Tank: 1500 Equivalent Sizing: 60% 75% 100%
 Final Disposal: Ft2 Lines: Length: Width: Depth:
 Gravel-less chambers: Number of Units: Number of Rows:
 Lagoon Bottom Size: 15x15 Depth: 6' Slopes: 2:1 Lining: 18" clay

COMMENTS: Top 39x39

Maintain lagoon at least 80' from property line.
 Watch grade from tank to lagoon.
 Fence lagoon with woven wire and posts spaced
 at a maximum of 10 ft.

AK [Signature] 11-23-99
 Environmental Health Specialist Date:

FINAL INSPECTION

The above system has been inspected and found to comply with the above requirements.

Owner Patricia Kenneman Nov 9, 99
 System Installer Environmental Health Specialist Date:

Asst
PPI

Meadows — Howard — Lt Boss

