

1994  
SAN JUAN BASIN  
**HEALTH**  
DEPARTMENT

Permit # 153-A

APPLICATION to Install, Construct, Alter, or Repair Individual Sewage System

Owner: Marvin Lord Phone: 931-5147  
Mailing Address: PO Box 547 Pagosa Spr Co 81147  
Site Address: 290 Brass Assessors Parcel # \_\_\_\_\_  
Subdivision: Meadow IV Unit 4 Block \_\_\_\_\_ Lot 249  
1. Lot size: 5 acres 3. Living units: 1  
2. Water supply: Central 4. Number of bedrooms: 3

This system will be constructed in accordance with the SJBHD individual sewage disposal systems regulations.

Date: 4/12/94 Applicant: Marvin Lord  
Permit fee: \$ 150.00 Received by: check # 1248 Date: 12 April '94

PERMIT to Install, Construct, Alter or Repair Individual Sewage System

Percolation Rate: 760 Min/Inch Limiting zone: — Feet: 78  
Soil Profile: Decomposed shale/clay % Slope: 5-10 Requires Eng. Design: optional  
From the application information and the site evaluation, the following minimum installation specifications are required:  
Tank: 1500 Septic Aeration  
Final Disposal: \_\_\_\_\_ F2 Lines \_\_\_\_\_ Length \_\_\_\_\_ Width \_\_\_\_\_ Max. Depth \_\_\_\_\_  
Lagoon: Bottom size 15x15 Depth 6' Total Slopes 2:1 Lining clay if necessary  
COMMENTS: 10x22

*Follow included design.  
Maintain required setbacks  
Fence the lagoon 40" high, posts 10ft apart.*

Royce Kinnaman 19 April 94  
Environmental Health Specialist Date

FINAL INSPECTION

Location of tank/control panel: \_\_\_\_\_  
The above system has been inspected and found to comply with the above permit requirements:

System Installer: Owner/SMTH  
Rev: 5/91 Gar Wilson 11/15/93  
Environmental Health Specialist Date

